

## Structure of Steam Room

### Procedure

### Comments

- Check seating for safe and satisfactory installation
- Check door fitting and closing action

---

---

## Steam Room Fixtures and Fittings

### Procedure

### Comments

- Check fitting of lights
- Check fitting of steam jet
- Check fitting of drain nozzle
- Check fitting of temperature control device

---

---

---

---

## Electricity Supply

### Procedure

### Comments

- Check integrity of supply and earthing system
- Check all connections and terminals

---

---

## Water Supply

### Procedure

### Comments

- Check integrity of water supply

---

## Control Panel

- Check operation of control panel

---

## Commissioning Procedure

### Procedure

### Comments

- Ensure satisfactory delivery of steam into room
- Run up to 30°C, maintain for ½ hour
- Run up to 40°C, maintain for 1 hour
- Shut down and ensure backwash operation
- Check operation of lighting
- Check automatic essence injector and cleaner function

---

---

---

---

---

---

## Further Details

---

## Completion Details

Signed by Engineer: \_\_\_\_\_ Date: \_\_\_\_\_

Ensure that Requirements for installation form is correctly filled out and accompanies this form.

---

